

Water

Sewer

Re-Use

Preferred Marker: 3M EMS 4” Ball Marker  
1403-XR

3M EMS 4” Ball Marker  
1404-XR

3M EMS 4” Ball Marker  
1408-XR

Alternate Markers: 3M EMS Mid-Range Marker  
1257  
3M EMS Full-Range Marker  
1252

3M EMS Mid-Range Marker  
1258  
3M EMS Full-Range Marker  
1253

Required Placement: All bends 22.5 degrees or larger, all capped or plugged ends, repair points, all tee’s and crosses, any change in pipe material, any change in direction.

Gravity – Service lateral cap.

Vacuum – Wyes, top of lifts, change in direction, diversions, all capped or plugged ends, service laterals.


Forcemains – All bends 22.5 degrees or larger, all capped or plugged ends, repair points, all tee’s and crosses, any change in pipe material, any change in direction.

All bends 22.5 degrees or larger, all capped or plugged ends, repair points, all tee’s and crosses, any change in pipe material, any change in direction.

\* All markers to be installed per manufacturers recommended spacing and depth.

LAST REVISION	MAR 2025
CHECKED	MM
APPROVED	KRL

**LOCATOR DEVICE**



**ENGLEWOOD WATER DISTRICT**  
**201 SELMA AVENUE**  
**ENGLEWOOD, FLORIDA 34223**