


ELEVATION OF 6" AIR INTAKE SHALL BE BASED ON FEMA FLOOD PLAIN MAPS

SCH. 40 COUPLING GLUED ON BOTTOM ONLY 12" ABOVE FINISHED GRADE (PAINT TO MATCH VENT)



AREA OF 6" PIPE = 28.26 SQ. IN.
AREA OF (8) x 2 1/2" HOLES= 39.25 SQ. IN.


VENT DETAIL

NOTE:

1. ONLY ONE INTAKE PER VALVE PIT.
2. VENT MUST BE PAINTED WITH RUSTOLEUM 7733 DARK HUNTER GREEN GLOSS PAINT
3. THE RECIPIENT AGREES NOT TO REPRODUCE, COPY, INFORMATION THEREIN CONTAINED IN WHOLE OR IN ANY PURPOSE EXCEPT WITH THE WRITTEN PERMISSION SURRENDER SAME TO AIRVAC, INC. UPON DEMAND.

LAST REVISION	APRIL 2024
CHECKED	MM
APPROVED	KRL

6" AIR INTAKE



ENGLEWOOD WATER DISTRICT
201 SELMA AVENUE
ENGLEWOOD, FLORIDA 34223