



ENGLEWOOD WATER DISTRICT

201 Selma Ave
Englewood, FL 34223
(941) 474-3217

To: Prospective Bidders

Date: November 16, 2021

Re: **Addendum #1 to RFB 2022-127 Replacement of Lime Plant Filter Media No. 2**

Bid Closing Date: 2:15 p.m. (EST), November 18, 2021

Bidders are notified that this Addendum will be made part of the bid documents. The intent of the Addendum is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the bid price. These items have the same force and effect as if contained in the original documents.

QUESTIONS/ANSWERS

Q1: What would be the projected value of this project?

A1: *The estimate for this work is approximately \$35,000.*

Q2: Does the city have a preferred supplier of the wheeler bottoms from previous projects?

A2: *The District will supply the wheeler bottoms.*

Q3: If we are to replace any bottoms how many extra days will be added to the contract?

A3: *Please refer to the Technical Specifications Section 1.5. The successful Bidder will commence work within thirty (30) days of notification to the Bidder after the District receives the filter media and will complete all work described in the Technical Specifications within 3 weeks (4 weeks if Wheeler bottoms need replacement).*

Q4: Is there a fire hydrant nearby? If so, what is the operating psi?

A4: *There is a fire hydrant within 200' of the filters. The operating pressure is approximately 60 psi.*

Q5: When is the city planning on issue the Notice of Award to the low bidder?

A5: *All purchases over \$25K must have Board approval. The next scheduled Board Meeting is December 2, 2021. Staff plans to request approval from the Board for the low bidder at this meeting. If approved, the Notice of Award will be issued following that meeting.*

Bidders are required to acknowledge receipt of this addendum in their bid forms.

Bee Ling Wheaton

Bee Ling Wheaton, Purchasing Manager