


NOTES:

1. THRUST BLOCKS MAY BE USED IN LIEU OF MECHANICAL RESTRAINT IN THIS AREA.
2. COORDINATE DEACTIVATION OF EXISTING MAIN WITH ENGLEWOOD WATER DISTRICT
3. DISINFECTION (WATER MAIN ONLY)

LAST REVISION	FEB. 2019
CHECKED	MM
APPROVED	KRL

MAIN RELOCATION DETAIL



ENGLEWOOD WATER DISTRICT
 201 SELMA AVENUE
 ENGLEWOOD, FLORIDA 34223