


LIMEROCK BASE SHALL BE COMPACTED TO AN AVG. DENSITY NOT LESS THAN 98% OF MAX DENSITY AS DETERMINED BY AASHTO T180.

BACKFILL TRENCH W/SUITABLE MATERIAL IN LAYERS NOT TO EXCEED 12" TO AN AVG. DENSITY NOT LESS THAN 100% OF MAX. DENSITY AS DETERMINED BY AASHTO T99.

NOTE:  
EXISTING SURFACE AND BASE TO BE CUT SQUARE WITH CONCRETE SAW

LAST REVISION	FEB. 2019
CHECKED	MM
APPROVED	KRL

**REPLACEMENT OF CONCRETE DRIVES**



**ENGLEWOOD WATER DISTRICT**  
201 SELMA AVENUE  
ENGLEWOOD, FLORIDA 34223