

RUN	BRANCH											
	4"		6"		8"		10"		12"		16"	
	L	H	L	H	L	H	L	H	L	H	L	H
4"	15	20										
6"	15	20	23	30								
8"	15	20	23	30	31	39						
10"	15	20	23	30	31	39	40	48				
12"	15	20	23	30	31	39	40	48	48	57		
16"	15	20	23	30	31	39	40	48	48	57	62	78
18"	15	20	23	30	31	39	40	48	48	57	62	78
20"	15	20	23	30	31	39	40	48	48	57	62	78
24"	15	20	23	30	31	39	40	48	48	57	62	78
30"	15	20	23	30	31	39	40	48	48	57	62	78

NOTES:

1. ALL TAPPING SLEEVES SHALL BE STAINLESS
2. BOLTS ARE NOT TO BE COVERED WITH CONCRETE


* UTILITY APPROVED MJ TAPPING VALVE

LAST REVISION FEB. 2019

CHECKED MM

APPROVED KRL

**STANDARD TAPPING
SLEEVE AND VALVE**



ENGLEWOOD WATER DISTRICT
201 SELMA AVENUE
ENGLEWOOD, FLORIDA 34223