


NOTES:

1. ALL BOXES INSTALLED BY DEVELOPER – THE ONE UNIT METER TO BE INSTALLED BY EWD.
2. ALL METER WORK TO BE COORDINATED WITH EWD.
3. NO SOLVENT JOINTS ARE TO BE USED.
4. ALL 1" METERS ARE REQUIRED TO HAVE A 1" REDUCED PRESSURE BACKFLOW PREVENTION ASSEMBLY INSTALLED IMMEDIATELY DOWNSTREAM OF THE METER.

LAST REVISION	FEB 2019
CHECKED	MM
APPROVED	KRL

**TYPICAL SERVICE TAP WITH
1" REMOTE READING METER**



ENGLEWOOD WATER DISTRICT
 201 SELMA AVENUE
 ENGLEWOOD, FLORIDA 34223