



ENGLEWOOD WATER DISTRICT

201 Selma Ave
Englewood, FL 34223
(941) 474-3217

To: Prospective Bidders

Date: May 12, 2023

Re: **Addendum #1 to RFB 2023-134 V1 Vacuum Station Improvements Project**

Bid Closing Date: 2:15 p.m. (EST), June 21, 2023

Bidders are notified that this Addendum will be made part of the bid documents. The intent of the Addendum is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the bid price. These items have the same force and effect as if contained in the original documents.

QUESTIONS/ANSWERS

Q1: What is the Engineer's Estimate for this project?

A1: *The Engineer's Estimate is not available for this project. According to Florida State Statute 337.168: A document or electronic file revealing the official cost estimate of the department of a project is confidential and exempt from the provisions of s. 119.07(1) until the contract for the project has been executed or until the project is no longer under active consideration.*

ADDITIONS

1. The following language will be added to SP-13 Performance Period in Special Provisions, Page SP4:

The Contractor shall ensure that the existing vacuum station shall be out of service for no more than 60 days. The District will issue a notice upon start-up of the temporary system indicating the time period in which the Contractor will have to complete the required repairs and have the new permanent vacuum station operational. Failure to have the permanent vacuum station operational by the specified time may result in liquidated damages or other remedies available under the contract or by law, at the District's sole discretion.

2. The following clause will be added on as SPC 115 in Supplemental Provisions – Construction.

SALVAGE

Salvaged materials, equipment, or supplies identified on the project plans shall be deemed the property of the Englewood Water District. The Contractor shall identify such salvage items in cooperation with the District and ensure their delivery to the same, unless otherwise noted. Should the District choose not to accept these materials, the Contractor shall remove them from the project site at the earliest possible time. All materials shall be disposed of in accordance with state and local laws, in a lawful manner, and at no additional cost to the District. If applicable, the Contractor shall contact the District to coordinate the delivery of salvage materials.

Bidders are required to acknowledge receipt of this addendum in their bid forms.

Bee Ling Wheaton

Bee Ling Wheaton, Purchasing Manager